

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 79

Dated : 07/07/25

It is certified that an inspection team headed by Shivam Mishra (E.E.) (Name of Officer with Designation) From Jal. kund. Vishay Nigam Prayagraj (Name of Department/ Office) inspected the **PTS SCHOOL AND COLLEGE, BASAHARA MEJA PRAYAGRA (U.P.)** (Name & Address of the School) on 07/07/25 (Date of Inspection) and on the basis of Water test Report (Attached) bearing No. 79 dated 20/07/25 of Jal. kund. Vishay (PHED Lab) certified that the **PTS SCHOOL AND COLLEGE** (Name of the School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 3 months.

अधिसारी अभिवृत्त (मु०)
 उत्कल विभाग
 Signature with Seal:
 Name : Shivam Mishra
 Designation : E.E (HQ)
 Name & Address of the office / Department:

To,

MANAGER,

PTS SCHOOL AND COLLEGE

BASAHAHA, MEJA PRYAGRAJ

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



अधिकासी अधियन्ता (मु०)
जलकल विभाग-नगर निगम प्रयागराज
सं० ७९ मु०ज०क०वि०
दि०ंक ११/०७/२०२५

JAL KAL VIBHAG NAGAR NIGAM PRAYAGRAJ CHEMICAL ANALYSIS LABORATORY

Report No. DW/01/LAB2025-07/03

Date: 10.07.2025

DRINKING WATER ANALYSIS REPORT

1	Name & Address	PTS SCHOOL AND COLLEGE, BASAHAHA, MEJA- PRAYAGRAJ
2	Sample Collected by	By Party
3	Nature of Sample	Drinking Water (R.O)
4	Date of Sample Collection	07.07.2025
5	Date of Sample Receiving	07.07.2025
6	Date of Analysis Completed	10.07.2025

S.N.	PHYSICAL PARAMETERS	UNITS	OBSERVED VALUE	STANDARDS (IS 10500-2012)	
				Desirable Limit	Permissible Limit
1.	Colour, units.	-	Colourless	-	-
2.	Odour	Agreeable	Odourless	Agreeable	
3.	Temperature	°C	27.1	-	-
4.	Turbidity	NTU	1.8	5	10
5.	Conductivity at 25°C	µmho/cm	171.0	-	-
CHEMICAL PARAMETERS					
6.	pH	-	6.8	6.5 to 8.5	No Relaxation
7.	Suspended Solids	mg/L	Nil	-	-
8.	Dissolved Solids	mg/L	82.0	500	2000
9.	Total Solids	mg/L	82.0	-	-
10.	Total Alkalinity (as CaCO ₃)	mg/L	108.2	200	600
11.	Total Hardness (as CaCO ₃)	mg/L	30.0	200	600
12.	Chlorides (as Cl)	mg/L	19.0	250	1000
13.	Fluoride (as f) mg/l	mg/L	NIL	1.0	1.5
14.	Nitrate (as NO ₃)	mg/L	0.21	45.0	100.0
15.	Iron (Fe)	mg/L	NIL	0.3	1.0
BACTERIOLOGICAL PARAMETERS					
16.	Total Coliform	MPN/100ml	Absent	Absent	-
17.	E. Coli	MPN/100ml	Absent	Absent	-

*Note: The water is suitable for drinking purposes-

Analyst

JE(HQ)

अधिकासी अधियन्ता (मु०)
जलकल विभाग
E.E(HQ)
नगर निगम-प्रयागराज

- Note:
1. The above results are related only to the test performed on the sample.
 2. This report is not to be reproduce wholly or in part and can not be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.
 3. Sample will be destroyed in the after fifteen days from the date of reporting.